



OKLAHOMA
DEPARTMENT OF ENVIRONMENTAL QUALITY
...for a clean, attractive, prosperous Oklahoma

ENVIRONMENTAL COMPLAINTS & LOCAL SERVICES
TOTAL RETENTION FACILITIES
TOTAL RETENTION FACILITIES with LAND APPLICATION
SELF REPORTING WASTEWATER BYPASS FORM
(To be submitted within five (5) days of occurrence.)

MAILED

Date: 3-12-08 DEQ Facility ID: 20902 OPDES/NPDES ID: N/A
Facility/Municipality Name: TOWN OF BUFFALO OK

Report all Total Retention Facility and Total Retention Facilities with Land Application wastewater bypasses to DEQ within 24 hours at: **1-800-522-0206**
Mail written report within 5 days to: Department of Environmental Quality
Environmental Complaints and Local Services
P.O. Box 1677
Oklahoma City, OK 73101-1677

DEQ notified within 24 hours of bypass on: Date DEQ notified: 3-10-08
Time called in: Approx. 11:00AM

Type of bypass: Pipe Lagoon/Basin Manhole Head Works Lift Station
 Other (specify): _____

Strength of bypass: Raw Partially Treated Amount of Bypass: 5000+ (estimate only)
Period of bypass: From 3 10 2008 11:00 AM PM
To 3 10 2008 4:00 AM PM
Month Day Year Time

Were fish or other wildlife affected as a result of the bypass? Yes No

Type of samples taken: BOD TSS Fecal pH None Other: _____

Geographical location of bypass (including outfall number or receiving stream if appropriate):
6 cell

Reason for bypass: lagoon dam leaked

Steps taken to prevent recurrence: 1) dammed up to fix dyke 2) draining cell to dry out and fix

Impact to receiving stream and/or surrounding areas: leached into ground area adjacent to cell. No stream impacted.

Steps taken to clean up or treat bypass: None needed.

Reported by: Joe McVicker Title: City Manager

Signature: Joe McVicker by Linda Johnson Date: 3-12-08

6/2/04 Witt 3-12-08 City Clerk Include copies of ANY test results. DEQ Form #605-004